

SUBJECT: Indexing of Panelboards

EFFECTIVE DATE: May 2002

INTERPRETATION NUMBER: ADM – 4.0384.1

SEE ALSO: 1999 NEC – Article 384-13

INTERPRETATION SUMMARY

This article requires that all circuits in panelboards are to be identified on the face or inside of the door of the panelboard. It is the interpretation of this department that this requirement applies to all circuits in new panelboards, not only those new circuits that are being added to a new panelboard. Whenever a new panelboard is installed all circuits must be identified.